



NOTES:

1. AIR-RELEASE AND VALVE ASSEMBLIES SHALL BE INSTALLED AT HIGH POINTS. THE BREATHER TUBE SHALL EXTEND ABOVE GROUND AND PROVIDED WITH DOWNWARD FACING, SCREENED ELBOW.
2. PIPE AND VALVE SIZES SHALL BE SPECIFIED FOR EACH PROJECT BY THE ENGINEER.

**WINSTON-DILLARD WATER DISTRICT**

**COMBINATION AIR-RELEASE AND  
VACUUM VALVE ASSEMBLY**  
(ARI MODEL D-040)

DATE:

DRAWING NO.